

# NOTICE

In addition to the requirements of the  
“Roofing Inspection Checklist”  
as of October 1, 2018 Connecticut adopted the  
“2018 Connecticut State Building Code”  
Where Section R905.1.1 further requires:

**All joints in roof deck to be taped with minimum 4” wide,  
ASTM D 1970 compliant product**

**Applies to new roofs and strip/re-roof projects**

Exceptions:

- Roofs completely covered with self-adhered membrane
- Roof sheathing with nominal width less than 3-feet

---

***You must schedule so an inspection takes place while  
stripping and/or prior to applying any new shingles.  
Please schedule at least 48 hours in advance.***